			1. CONTRACT	ID CODE	PAGE OF PAGES	
AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT					1 2	
2. AMENDMENT/MODIFICATION NO. 3	3. EFFECTIVE DATE 8/20/09	4. REQUISITION/PUR			Γ NO. (If applicable)	
6. ISSUED BY CODE 7. A CONTRACTING OFFICER, USDA-ARS-NPA		7. ADMINISTERED BY	ADMINISTERED BY (If other than Item 6) CODE			
2150 Centre Avenue, Building D, Su						
Fort Collins, CO 80526		,				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) 9A. AMENDMENT OF SOLICITATION NO.						
X				AG-82HW-S-09-0017		
			9B. DATE (SEE ITEM 11)			
$\mid X \mid$			X 7/28/09	7/28/09		
				10A. MODIFICATION OF CONTRACT/ORDER		
			NO.			
,						
CODE FACILITY CODE			10B. DATED (S	10B. DATED (SEE ITEM 13)		
CODE 11 THIS	ITEM ONLY APPLIES	TO AMENDMENTS (OF SOLICITATIO	NS		
The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, 🔀 is not extended.						
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:						
(a) By completing Items 8 and 15, and returning 1, copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer						
submitted: or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDG-						
MENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or						
letter, provided each telegram or letter makes reference to this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACT/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
(a) A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MDE IN THE CON-						
TRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying offices, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
DOTUED (Consider two of modification and outhority)						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section heading, including solicitation/contract subject matter where feasible.)						
1. See page 2 for a correction and an answer to a question.						
		6 (I (I)		. blask 44 s	-h	
Offerors are cautioned to acknowledge this amendment by one of the methods described in block 11 above.						
Except as provided herein, all terms and conditions of this document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force						
and effect. 15A. NAME AND TITLE OF SIGNER (Type or print) 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)						
TOAL NAME AND THEE OF SIGNER (Type OF F	/				, , ,	
		JAMES C. WIL	TSE, Contracting	Officer	1 400 0 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNE		TES OF AMERICA		16C DATE SIGNED	
(Signature of person authorized to sign)	_	BY Signatu	re of Contracting Off	ficer)	18/20/09	

On page 13 of the Solicitation, clause F.1, where it states "the number of days required to complete the entire work ready for use not later than 180 days after receipt of receipt of notice to proceed" is in error. The number of days required to complete the entire work ready for use is hereby changed to not later than 270 calendar days after receipt of receipt of notice to proceed, in Clause F.1 on page 13 of the solicitation.

Question and Answer

Question: Does the roofing materials, walkways, pavers and coping need to be covered under one manufacturer's warranty?

Answer: Yes multiple manufacturers' warranties are acceptable, but the membrane manufacturer has to provide an overall system warranty to ensure that the components are compatible.